


# 3MXS40K (Cooling)




3D052818C

## NOTES

- Overall (dB):  
(B,G,N is already rectified)
- Measuring place: Measured in an anechoic room
- Operation noise differs with operation and ambient conditions.
- Operating conditions: Power source 220~240V, 50Hz
- Location of microphone.  
JISC9612  
The operation noise measuring method is in accordance with JISC9612

Scale	50Hz	220V~240V
A		46

# 3MXS40K (Heating)



3D052818C

## NOTES

- 1 Overall (dB):  
(B,G,N is already rectified)
- 2 Measuring place: Measured in an anechoic room
- 3 Operation noise differs with operation and ambient conditions.
- 4 Operating conditions: Power source 220~240V, 50Hz
- 5 Location of microphone.  
JISC9612  
The operation noise measuring method is in accordance with JISC9612

Scale	50Hz	220V~240V
A		47