

| | | | | | FUQ71CVEB / RZQSG71L3V1B | FUQ100CVEB / RZQSG100L9V1B | FUQ125CVEB / RZQSG125L9V1B |
|--|--|----------------------------|---|--|--------------------------|----------------------------|----------------------------|
| Poff (Off mode) | W | | | | 0.0 | 0.0 | 0.0 |
| Cooling | Psb (Standby mode cooling) | | | W | 7.0 | 7.0 | 7.0 |
| | Cooling--Cooling cdc degradation cooling | | | | 0.25 | 0.25 | 0.25 |
| Eurovent | Sound power level indoor | Cooling | Nom. | dBA | 59 | 64 | 65 |
| | Sound power level outdoor | Cooling | Nom. | dBA | 65 | 70 | 70 |
| Seasonal efficiency (according to EN14825) | Cooling | | Pdesign | kW | 6.80 | 9.50 | 12.00 |
| | | | Annual energy consumption | kWh | 410 | 593 | 793 |
| | | | | Seasonal efficiency (according to EN14825)--Cooling--Seasonal efficiency according to en14825 cooling energy label | A+ | A+ | A |
| | | | | Seasonal efficiency (according to EN14825)--Cooling--Seasonal efficiency according to en14825 cooling seer | 5.81 | 5.61 | 5.30 |
| | | D Condition (20°C - 27/19) | Pdc | kW | 3.81 | 4.02 | 3.96 |
| | | | | Seasonal efficiency (according to EN14825)--Cooling--D Condition (20°C - 27/19)--Eerd | 10.81 | 9.63 | 10.43 |
| | | C Condition (25°C - 27/19) | Pdc | kW | 3.65 | 4.59 | 5.69 |
| | | | | Seasonal efficiency (according to EN14825)--Cooling--C Condition (25°C - 27/19)--Eerd | 7.91 | 7.23 | 7.33 |
| | | A Condition (35°C - 27/19) | Pdc | kW | 6.80 | 9.50 | 12.00 |
| | | | | Seasonal efficiency (according to EN14825)--Cooling--A Condition (35°C - 27/19)--Eerd | 3.21 | 3.21 | 2.65 |
| | | B Condition (30°C - 27/19) | Pdc | kW | 5.01 | 7.00 | 8.84 |
| | | | | Seasonal efficiency (according to EN14825)--Cooling--B Condition (30°C - 27/19)--Eerd | 3.86 | 3.73 | 3.01 |
| | Heating (Average climate) | | Annual energy consumption | kWh | 2,273 | 2,654 | 2,764 |
| | | | Pdesign | kW | 6.33 | 7.60 | 7.60 |
| | | | Required back up heating cap at design conditions | kW | 0.63 | 0.56 | 0.55 |
| | | | | Seasonal efficiency (according to EN14825)--Heating (Average climate)--Seasonal efficiency according to en14825 heating average climate scop a | 3.90 | 4.01 | 3.85 |
| | | | | Seasonal efficiency (according to EN14825)--Heating (Average climate)--Seasonal efficiency according to en14825 heating average climate energy label | A | A+ | A |
| | | TBivalent | Pdh (declared heating cap) | kW | 5.60 | 6.72 | 6.72 |
| | | | Tbiv (bivalent temperature) | °C | -7 | -7 | -7 |

| | | | | | | | |
|-----------------------------|--|--------------------|-----------------------------------|--|-------------------|-------------------|-------------------|
| | | | | Seasonal efficiency (according to EN14825)--Heating (Average climate)--TBivalent--Copl declared cop | 2.44 | 2.69 | 2.62 |
| | | C Condition (7°C) | Pdh (declared heating cap) | kW | 2.86 | 3.02 | 3.03 |
| | | | | Seasonal efficiency (according to EN14825)--Heating (Average climate)--C Condition (7°C)--Copl declared cop | 5.41 | 5.56 | 5.26 |
| | | TOL | Tol (temperature operating limit) | °C | -15 | -15 | -15 |
| | | | Pdh (declared heating cap) | kW | 5.87 | 7.56 | 7.60 |
| | | | | Seasonal efficiency (according to EN14825)--Heating (Average climate)--TOL--Copl declared cop | 1.73 | 1.89 | 1.88 |
| | | A Condition (-7°C) | Pdh (declared heating cap) | kW | 5.60 | 6.72 | 6.72 |
| | | | | Seasonal efficiency (according to EN14825)--Heating (Average climate)--A Condition (-7°C)--Copl declared cop | 2.44 | 2.69 | 2.62 |
| | | D Condition (12°C) | Pdh (declared heating cap) | kW | 3.25 | 3.44 | 3.46 |
| | | | | Seasonal efficiency (according to EN14825)--Heating (Average climate)--D Condition (12°C)--Copl declared cop | 6.31 | 6.59 | 6.24 |
| | | B Condition (2°C) | Pdh (declared heating cap) | kW | 3.46 | 4.13 | 4.14 |
| | | | | Seasonal efficiency (according to EN14825)--Heating (Average climate)--B Condition (2°C)--Copl declared cop | 3.88 | 3.82 | 3.68 |
| Cooling capacity | Nom. | | | kW | 6.80 | 9.5 | 12.0 |
| Pck (Crankcase heater mode) | W | | | | 0.0 | 0.0 | 0.0 |
| Nominal efficiency | Annual energy consumption | | | kWh | 1,060 | 1,480 | 2,265 |
| | Energy label | | | Heating | A | A | B |
| | | | | Cooling | A | A | D |
| | Nominal efficiency--Cop | | | | 3.61 | 3.61 | 3.41 |
| | Nominal efficiency--Eer | | | | 3.21 | 3.21 | 2.65 |
| Heating | Heating--Heating cdh degradation heating | | | | 0.25 | 0.25 | 0.25 |
| Heating capacity | Nom. | | | kW | 7.50 | 10.8 | 13.5 |
| Pto (Thermostat off) | W | | | | 7.0 | 7.0 | 7.0 |
| Power input | Cooling | | Nom. | kW | 2.12 | 2.96 | 4.53 |
| | Heating | | Nom. | kW | 2.08 | 2.99 | 3.95 |
| Template | | | | | Split Sky Air Set | Split Sky Air Set | Split Sky Air Set |
| Cold season included | | | | | No | No | No |
| Average climate included | | | | | Yes | Yes | Yes |
| Warm season included | | | | | No | No | No |
| Heating function included | | | | | Yes | Yes | Yes |

| | | | | | | | |
|--|---------------------------|----------------------------|---|--|-------|-------|--|
| | | | | Seasonal efficiency (according to EN14825)--Cooling--Seasonal efficiency according to en14825 cooling seer | 5.61 | 5.30 | |
| | | D Condition (20°C - 27/19) | Pdc | kW | 4.02 | 3.96 | |
| | | | power input | kW | 0.42 | 0.38 | |
| | | | | Seasonal efficiency (according to EN14825)--Cooling--D Condition (20°C - 27/19)--Eerd | 9.63 | 10.43 | |
| | | C Condition (25°C - 27/19) | power input | kW | 0.64 | 0.78 | |
| | | | Pdc | kW | 4.59 | 5.69 | |
| | | | | Seasonal efficiency (according to EN14825)--Cooling--C Condition (25°C - 27/19)--Eerd | 7.23 | 7.33 | |
| | | A Condition (35°C - 27/19) | power input | kW | 2.96 | 4.53 | |
| | | | Pdc | kW | 9.50 | 12.00 | |
| | | | | Seasonal efficiency (according to EN14825)--Cooling--A Condition (35°C - 27/19)--Eerd | 3.21 | 2.65 | |
| | | B Condition (30°C - 27/19) | Pdc | kW | 7.00 | 8.84 | |
| | | | power input | kW | 1.88 | 2.94 | |
| | | | | Seasonal efficiency (according to EN14825)--Cooling--B Condition (30°C - 27/19)--Eerd | 3.73 | 3.01 | |
| | Heating (Average climate) | | Annual energy consumption | kWh | 2,654 | 2,764 | |
| | | | Pdesign | kW | 7.60 | 7.60 | |
| | | | Required back up heating cap at design conditions | kW | 0.56 | 0.55 | |
| | | | | Seasonal efficiency (according to EN14825)--Heating (Average climate)--Seasonal efficiency according to en14825 heating average climate scopnet a | 4.02 | 3.86 | |
| | | | | Seasonal efficiency (according to EN14825)--Heating (Average climate)--Seasonal efficiency according to en14825 heating average climate pdh heating capacity at 10 | 7 | 7 | |
| | | | | Seasonal efficiency (according to EN14825)--Heating (Average climate)--Seasonal efficiency according to en14825 heating average climate scop a | 4.01 | 3.85 | |
| | | | | Seasonal efficiency (according to EN14825)--Heating (Average climate)--Seasonal efficiency according to en14825 heating average climate energy label | A+ | A | |
| | | TBivalent | Pdh (declared heating cap) | kW | 6.72 | 6.72 | |
| | | | Power input | kW | 2.50 | 2.57 | |
| | | | Tbiv (bivalent temperature) | °C | -7 | -7 | |
| | | | | Seasonal efficiency (according to EN14825)--Heating (Average climate)--TBivalent--Copd declared cop | 2.69 | 2.62 | |

| | | | | | | | |
|-----------------------------|--|--------------------|-----------------------------------|--|-------------------|-------------------|--|
| | | C Condition (7°C) | Pdh (declared heating cap) | kW | 3.02 | 3.03 | |
| | | | Power input | kW | 0.55 | 0.58 | |
| | | | | Seasonal efficiency (according to EN14825)--Heating (Average climate)--C Condition (7°C)--Copd declared cop | 5.56 | 5.26 | |
| | | TOL | Tol (temperature operating limit) | °C | -15 | -15 | |
| | | | Pdh (declared heating cap) | kW | 7.56 | 7.60 | |
| | | | Power input | kW | 4.00 | 4.05 | |
| | | | | Seasonal efficiency (according to EN14825)--Heating (Average climate)--TOL--Copd declared cop | 1.89 | 1.88 | |
| | | A Condition (-7°C) | Pdh (declared heating cap) | kW | 6.72 | 6.72 | |
| | | | Power input | kW | 2.50 | 2.57 | |
| | | | | Seasonal efficiency (according to EN14825)--Heating (Average climate)--A Condition (-7°C)--Copd declared cop | 2.69 | 2.62 | |
| | | D Condition (12°C) | Pdh (declared heating cap) | kW | 3.44 | 3.46 | |
| | | | Power input | kW | 0.53 | 0.56 | |
| | | | | Seasonal efficiency (according to EN14825)--Heating (Average climate)--D Condition (12°C)--Copd declared cop | 6.59 | 6.24 | |
| | | B Condition (2°C) | Power input | kW | 1.09 | 1.13 | |
| | | | Pdh (declared heating cap) | kW | 4.13 | 4.14 | |
| | | | | Seasonal efficiency (according to EN14825)--Heating (Average climate)--B Condition (2°C)--Copd declared cop | 3.82 | 3.68 | |
| Cooling capacity | Nom. | | | kW | 9.5 | 12.0 | |
| Pck (Crankcase heater mode) | W | | | | 0.0 | 0.0 | |
| Nominal efficiency | Annual energy consumption | | | kWh | 1,480 | 2,265 | |
| | Energy label | | | Heating | A | B | |
| | | | | Cooling | A | D | |
| | Nominal efficiency--Cop | | | | 3.61 | 3.41 | |
| | Nominal efficiency--Eer | | | | 3.21 | 2.65 | |
| Heating | Psb (Standby mode heating) | | | W | 7.0 | 7.0 | |
| | Heating--Heating cdh degradation heating | | | | 0.25 | 0.25 | |
| Heating capacity | Nom. | | | kW | 10.8 | 13.5 | |
| Pto (Thermostat off) | W | | | | 7.0 | 7.0 | |
| Power input | Cooling | | Nom. | kW | 2.96 | 4.53 | |
| | Heating | | Nom. | kW | 2.99 | 3.95 | |
| Template | | | | | Split Sky Air Set | Split Sky Air Set | |
| Indoor unit | | | | | FUQ100C | FUQ125C | |
| Outdoor unit | | | | | RZQSG100L8Y1 | RZQSG125L8Y1 | |
| Cold season included | | | | | No | No | |

| | | | | | | | |
|---------------------------|--|--|--|--|-----|-----|--|
| Average climate included | | | | | Yes | Yes | |
| Warm season included | | | | | No | No | |
| Heating function included | | | | | Yes | Yes | |
| Ecolabel logo | | | | | No | No | |
| Cooling function included | | | | | Yes | Yes | |